

Phase Contrast Microscopy Air Sampling Program, Medical Sciences Building, 1st Floor, University of Toronto, April 3, 2017

Floor	Room	Description	Sample Location	Sample Number	Pump Number	Litres Per Minute	Time On	Time Off	Duration	Total Litres	Total Fibres	Results f/cc	Analyst	Within Acceptable Limits	Comments
1	1209	Services	Central	2017-04-313	4	14.99	11:44	13:34	110	1649	3	0.001	SC/GS	Yes	Not occupied.
NA	NA	Exterior Control	South of Medical Sciences Building	2017-04-324	2	15.05	15:44	17:07	83	1249	3	0.001	SC/GS	Yes	Required as per NIOSH Method 7400.
NA	NA	Exterior Control	North of Medical Sciences Building	2017-04-325	3	15.01	15:49	17:13	84	1261	3	0.001	SC/GS	Yes	Required as per NIOSH Method 7400.
6	Field Blank	NA	NA	2017-04-326	NA	NA	NA	NA	NA	NA	0	Not applicable	Not applicable	Not applicable	Required as per NIOSH Method 7400.
6	Field Blank	NA	NA	2017-04-327	NA	NA	NA	NA	NA	NA	0	Not applicable	Not applicable	Not applicable	Required as per NIOSH Method 7400.
6	Field Blank	NA	NA	2017-04-328	NA	NA	NA	NA	NA	NA	0	Not applicable	Not applicable	Not applicable	Required as per NIOSH Method 7400.
6	Field Blank	NA	NA	2017-04-329	NA	NA	NA	NA	NA	NA	0	Not applicable	Not applicable	Not applicable	Required as per NIOSH Method 7400.

Safetech Environmental Limtied
3045 Southcreek Road, #14
Mississauga, Ontario
L4X 2X7

Tel: 905 624-2722
www.safetechenv.com



Interpretation of Results

- 1) Within Ontario, the Occupational Health and Safety Act - Ontario Regulation 490/09 Designated Substances adopts the ACGIH TWA of 0.1 fibres/cc.
- 2) For each area tested compare the "Results f/cc" column to your area and how it compares to the above noted regulation.