


Phase Contrast Microscopy Air Sampling Program, Medical Sciences Building, 4th Floor, University of Toronto, April 3, 2017															
Floor	Room	Description	Sample Location	Sample Number	Pump Number	Litres Per Minute	Time On	Time Off	Duration	Total Litres	Total Fibres	Results f/cc	Analyst	Within Acceptable Limits	Comments
4	4185S	Stairwell	Landing	2017-04-319	8	15.13	14:28	15:57	89	1347	7	0.002	SC/GS	Yes	Occupied.
4	4388S	Stairwell	Landing	2017-04-322	9	15.03	16:14	17:25	71	1067	6	0.002	SC/GS	Yes	Occupied.
4	4298S	Stairwell	Landing	2017-04-323	8	15.13	16:22	17:39	77	1165	2.5	0.001	SC/GS	Yes	Occupied.
NA	NA	Exterior Control	South of Medical Sciences Building	2017-04-324	2	15.05	15:44	17:07	83	1249	3	0.001	SC/GS	Yes	Required as per NIOSH Method 7400.
NA	NA	Exterior Control	North of Medical Sciences Building	2017-04-325	3	15.01	15:49	17:13	84	1261	3	0.001	SC/GS	Yes	Required as per NIOSH Method 7400.
6	Field Blank	NA	NA	2017-04-326	NA	NA	NA	NA	NA	NA	0	Not applicable	Not applicable	Not applicable	Required as per NIOSH Method 7400.
6	Field Blank	NA	NA	2017-04-327	NA	NA	NA	NA	NA	NA	0	Not applicable	Not applicable	Not applicable	Required as per NIOSH Method 7400.
6	Field Blank	NA	NA	2017-04-328	NA	NA	NA	NA	NA	NA	0	Not applicable	Not applicable	Not applicable	Required as per NIOSH Method 7400.
6	Field Blank	NA	NA	2017-04-329	NA	NA	NA	NA	NA	NA	0	Not applicable	Not applicable	Not applicable	Required as per NIOSH Method 7400.
<div><div><div>Safetech Environmental Limtied 3045 Southcreek Road, #14 Mississauga, Ontario L4X 2X7 Tel: 905 624-2722 www.safetechenv.com</div><div><div>Interpretation of Results</div><div>1) Within Ontario, the Occupational Health and Safety Act - Ontario Regulation 490/09 Designated Substances adopts the ACGIH TWA of 0.1 fibres/cc.</div><div>2) For each area tested compare the "Results f/cc" column to your area and how it compares to the above noted regulation.</div></div><div></div></div></div>															