

Phase Contrast Microscopy Air Sampling Program, Medical Sciences Building, Floor 3, University of Toronto, April 5, 2018															
Floor	Room	Description	Sample Location	Sample Number	Pump Number	Litres Per Minute	Time On	Time Off	Duration	Total Litres	Total Fibres	Results f/cc	Analyst	Within Acceptable Limits	Comments
3	3279	Janitor Closet	Central	2018-03-2795	6	15.06	13:43	15:23	100	1506	2	0.001	JC/GS	Yes	Vacant.
3	3292	Janitor Closet	Central	2018-03-2796	5	15.04	13:47	15:27	100	1504	5	0.002	JC/GS	Yes	Vacant.
3	3287K	Corridor	Central	2018-03-2797	8	15.03	13:50	15:29	99	1487.97	6	0.002	JC/GS	Yes	Occupied.
3	3280	Lab	Central	2018-03-2798	7	15	13:53	15:32	99	1485	3	0.001	JC/GS	Yes	Vacant.
3	3383K	Corridor	Central	2018-03-2799	9	15.02	13:58	15:35	97	1456.94	4.5	0.002	JC/GS	Yes	Occupied.
3	3365	Lunch Room	Central	2018-03-2800	10	15.05	14:04	15:39	95	1429.75	3	0.001	JC/GS	Yes	Occupied.
3	3350K	Corridor	Central	2018-03-2801	7	15	15:45	16:55	70	1050	3	0.001	JC/GS	Yes	Occupied.
3	3234	Elevator Lobby	Central	2018-03-2802	8	15.03	15:48	16:59	71	1067.13	2.5	0.001	JC/GS	Yes	Occupied.
3	3324K	Corridor	Central	2018-03-2803	10	15.05	15:52	17:04	72	1083.6	4.5	0.002	JC/GS	Yes	Occupied.
3	3309	Lab	Central	2018-03-2804	9	15.02	15:56	17:07	71	1066.42	1	0.001	JC/GS	Yes	Occupied.
		Exterior Control	North of Medical Sciences Building	2018-03-2805	6	15.06	16:07	17:19	72	1155.8	1	0.001	JC/GS	Yes	Exterior sample for comparison.
3	Field blank	NA	NA	2018-03-2806	NA	NA	NA	NA	NA	NA	0	Not applicable	Not applicable	Not applicable	Required as per NIOSH Method 7400.
3	Field Blank	NA	NA	2018-03-2807	NA	NA	NA	NA	NA	NA	0	Not applicable	Not applicable	Not applicable	Required as per NIOSH Method 7400.
3	Field Blank	NA	NA	2018-03-2808	NA	NA	NA	NA	NA	NA	0	Not applicable	Not applicable	Not applicable	Required as per NIOSH Method 7400.
3	Field Blank	NA	NA	2018-03-2809	NA	NA	NA	NA	NA	NA	0	Not applicable	Not applicable	Not applicable	Required as per NIOSH Method 7400.
Safetech Environmental Limited 3045 Southcreek Road, #14 Mississauga, Ontario L4X 2X7 Tel: 905 624-2722 www.safetechenv.com Interpretation of Results 1) Within Ontario, the Occupational Health and Safety Act - Ontario Regulation 490/09 Designated Substances adopts the ACGIH TWA of 0.1 fibres/cc. 2) For each area tested compare the "Results f/cc" column to your area and how it compares to the above noted regulation. 															