

Phase Contrast Microscopy Air Sampling Program, Medical Sciences Building, Floor 4, University of Toronto, April 7, 2017

Floor	Room	Description	Sample Location	Sample Number	Pump Number	Litres Per Minute	Time On	Time Off	Duration	Total Litres	Total Fibres	Results f/cc	Analyst	Within Acceptable Limits	Comments
4	4377	Lab	Central	2017-04-400	2	15.04	12:01	13:53	112	1684	2	0.001	SC/GS	Yes	Not Occupied.
4	4381	Lab	Central	2017-04-401	3	15.01	12:07	14:00	113	1696	4	0.001	SC/GS	Yes	Not Occupied.
4	4379	Lab	Central	2017-04-409	2	15.04	13:58	15:25	87	1308	2	0.001	SC/GS	Yes	Occupied.
	Exterior Control	NA	North of Medical Sciences Building	2017-04-410	3	15.01	14:48	16:15	87	1306	3	0.001	SC/GS	Yes	Exterior sample for comparison.
	Exterior Control	NA	South of Medical Sciences Building	2017-04-411	6	14.91	14:52	16:21	89	1327	2	0.001	SC/GS	Yes	Exterior sample for comparison.
6	Field blank	NA	NA	2017-04-412	NA	NA	NA	NA	NA	NA	0	Not applicable	Not applicable	Not applicable	Required as per NIOSH Method 7400.
6	Field Blank	NA	NA	2017-04-413	NA	NA	NA	NA	NA	NA	0	Not applicable	Not applicable	Not applicable	Required as per NIOSH Method 7400.
6	Field Blank	NA	NA	2017-04-414	NA	NA	NA	NA	NA	NA	0	Not applicable	Not applicable	Not applicable	Required as per NIOSH Method 7400.
6	Field Blank	NA	NA	2017-04-415	NA	NA	NA	NA	NA	NA	0	Not applicable	Not applicable	Not applicable	Required as per NIOSH Method 7400.

Safetech Environmental Lintied  
3045 Southcreek Road, #14  
Mississauga, Ontario  
L4X 2X7

Tel: 905 624-2722  
www.safetechenv.com



Interpretation of Results  
1) Within Ontario, the Occupational Health and Safety Act - Ontario Regulation 490/09 Designated Substances adopts the ACGIH TWA of 0.1 fibres/cc.  
2) For each area tested compare the "Results f/cc" column to your area and how it compares to the above noted regulation.